

University of Louisville
DEPARTMENT OF PROCUREMENT SERVICES
LOUISVILLE, KENTUCKY

Date: 8/22/2023

IFB No: IB-002-24

Title: 55A Tower and 55B Instructional Buildings Electrical Switchgear Replacement

Addendum No. 1

On the following pages the University has issued a response to written questions received.

Proposer must acknowledge receipt of this and any addenda either with their proposal submission or by separate letter. Acknowledgement must be received in the Department of Procurement Services, Service Complex Building, University of Louisville no later than **August 31st, 2023, at 2:00PM, EST.** If by separate letter, the following information must be placed in the lower left-hand corner of the envelope:

RFP No: IB-002-24

Due Date: August 31st, 2023, at 2:00PM, EST.

Evan Riddell
Digitally signed by Evan Riddell
Date: 2023.08.22 15:24:54 -04'00'

BY: _____
Authorized Purchasing Officer

Receipt Acknowledged: _____
FIRM

BY: _____

1. To confirm, the facility plans to have one shutdown only from Friday afternoon to Monday morning to perform for both switchgears consisting of demoing gear, installing new, extending feeders, and commissioning?

University Response: The plan is to have two separate shutdowns. One for 55A and one for 55B.

2. Freight elevator in building A maximum's weight capacity is 6,000lbs. The existing equipment has items exceeding that weight amount. Has the elevator ever pulled more than 6,000lbs before?

University Response: The 55a freight elevator has 6,000lbs rating with a 7,500lb maximum – contractors are not to exceed these weights.

3. Will the building be unoccupied during the shutdown?

University Response: The building will not be completely unoccupied.

4. Is there any requirement for an outdoor generator for temporary power and lighting for the building?

University Response: There is no plan to have a temporary generator.