



**PROCUREMENT SERVICES
ADDENDUM**

Date of Notice:	3/10/2025
Solicitation No.:	IB-016-25
Title:	Coal Boiler Removal and Abatement
Addendum No.:	1

The following pages shall clarify and/or modify the original bid document(s) as issued by the University of Louisville.

Proposer must acknowledge receipt of this and any addenda either with proposal or by separate letter. Acknowledgement must be received in the Department of Procurement Services, Service Complex Building, University of Louisville no later than **3/21/2025 at 12:00PM, EST**. If by separate letter, the following information must be placed in the lower left-hand corner of the envelope:

Solicitation No.:	IB-016-25
Title:	Coal Boiler Removal and Abatement
Due Date:	3/21/2025 at 12:00PM, EST.

Authorized By:

Procurement Services	
-------------------------	--

Receipt Acknowledged:

Company	
Signature	
Name (print)	
Date	

IB-016-25

Bidder Questions

1. On demolition plan M1.4, note M1 calls for the complete removal of exterior boiler breaching and structural support. Please confirm that this is included in the demolition scope.

UofL Response: Exterior breaching and support is not included as part of the coal boiler removal. The exterior breaching to be removed to the first seam to allow installation of a louver by others.

2. On demolition plan M1.4, note M12 calls for the complete removal of the exterior masonry boiler stack. Please confirm that this is included in the demolition scope. It was stated during the Prebid meeting that the stack demolition was not included in the scope.

UofL Response: The boiler stack is not included for this bid.

3. On demolition plan M1.4, please confirm that notes M16 through M22 are included in the demolition scope. These notes include relocating and the put back of materials.

UofL Response: These notes do not apply to the removal of the boiler.