



**PROCUREMENT SERVICES
ADDENDUM**

Date of Notice:	5/23/2025
Solicitation No.:	IB-029-25
Title:	UofL Belknap Campus Lighting Improvements
Addendum No.:	Three (3)

The following shall clarify and/or modify the original bid document(s) as issued by the University of Louisville.

1. Bid Opening

The bid opening has been moved from 5/28/2025 to **5/29/2025 at 10am, EST**. No change to location.

2. Questions and Answers

See Attachment A below.

Bidder must acknowledge receipt of this and any addenda either with bid or by separate letter. Acknowledgement must be received in the Department of Procurement Services, Service Complex Building, University of Louisville no later than **05/29/2025 at 10:00AM, EST**. If by separate letter, the following information must be placed in the lower left-hand corner of the envelope:

Solicitation No.:	IB-029-25
Title:	UofL Belknap Campus Lighting Improvements
Due Date:	05/29/2025

Authorized By:

Procurement Services	Jamie D. Peck
----------------------	---------------

Receipt Acknowledged:

Company	
Signature	
Name (print)	
Date	

Questions & Answers

UofL Belknap Campus Lighting Improvements

IB-029-25

1. **Q:** I was getting ready to roll off the conduit needed for the project, and I noticed the scale of 1/18" = 1'. Can you find out if this is the correct scale.

A: The scales included in the plan set are not accurate. Please reference General Site Work Note A stating "Do not scale from electrical drawings. Field verify required dimensions as required." Upon the engineer's approval, the installed quantity of material for "CONDUIT – 1 IN" and "TRENCHING AND BACKFILLING" will be recognized and paid.