

PROCUREMENT SERVICES ADDENDUM

Date of Notice:	7/18/2024
Solicitation No.:	IB-044-24
Title:	Life Sciences Generator Replacement
Addendum No.:	1

The following pages shall clarify and/or modify the original bid document(s) as issued by the University of Louisville.

Proposer must acknowledge receipt of this and any addenda either with proposal or by separate letter. Acknowledgement must be received in the Department of Procurement Services, Service Complex Building, University of Louisville no later than 7/25/2024 at 12:00PM, EST. If by separate letter, the following information must be placed in the lower left-hand corner of the envelope:

Solicitation No.:	IB-044-24
Title:	Life Sciences Generator Replacement
Due Date:	7/25/2024 at 12:00PM, EST.

Authorized By: Procurement

Services	
Receipt Acknowledged	l:
Company	
Signature	
Name (print)	
ivanie (print)	
Date	

Rev. 02.2024 Page 1 of 1

IB-044-24

Vendor Questions

1. Will the generator be on site, or do we have to bring it to the site from another location?

University Response: We have requested for the delivery to be at Site. Expected delivery Date is 1st week of September. Will update as the exact date gets closer.

2. Is the concrete pad at the northwest loading dock sufficient for operating a crane?

University Response: This area has tunnels and have weight limitations. See Exhibit G - Tunnel Documents for more information.

3. Is there a specific roofing contractor who holds the warranty on the roof that we have to use?

University Response: Roofs warranty is expired, and it will be replaced in separate project.

4. Will there be any noise restrictions when performing work during class hours?

University Response: Yes, any work related to noise shall NOT be performed during class hours. Work after class hours & on weekends is acceptable to us. More information will be shared as project progresses.

The Class hours Scheduled during the week is noted below.

Monday to Thursday: 8:00 AM- 6:45 PM

Friday: 8:00 AM – 2:15 PM

Saturday & Sunday: No courses